CIVIL XPERTS
ISO 9001:2008
CONSULTANTS & TESTING CENTER

174, Sri Ranga Complex
Amrutha Nagar Main Road
New Bank Colony, Konanakunte
Bangalore - 560 062.
Mobile : +91 97429 59595
Tele/Fax : 080-2632 2565
E-mail : civilexpertsltd@gmail.com
URL : www.civilexperts.in

NABL ACCREDITED AS PER ISO/IEC 17025:2005

JOB No: CECTC-PMC-NMK-2016-17

Dated:24.02.2017

TEST REPORT FOR EMBANKMENT SOIL

Client	:	**Executive Engineer,** Rajarajeshwarinagara Division, BBMP, Bangalore.
Agency	:	**Sri.N.M.Krishna Murthy,** Contractor, Bangalore.
Name of the Work	:	Modified Estimate for the Work of Development of Playground at Ward No.17 JP Park, BBMP, Bangalore.
Sample / Location	:	Embankment Soil
Date of sample taken for testing	:	23.02.2017

The results of the test Conducted on the sample is as follows.

Sl. No.	Name of Test	Test as per IS Code	Test Results
1	Determination of water Content-Dry Density Relation using heavy Compaction	IS 2720 Part 8	MDD = 1.88 g/cc OMC = 12.50 %
2	Grain size analysis (By wet sieving)	IS 2720(Part -4)1985 RA 2010	Gravel in % = 8.44 Sand in % =35.32 Silt & clay in % =56.24

Note:

⇒ The report shall not be reproduced, except in full, without the written approval of the laboratory.

⇒ The results indicated above are based on the tests carried out on the samples received in the laboratory.

⇒ Any Query regarding the report must be reported within 15 days from the date of testing.

For Civil Expert

Authorised Signature

ಸಹಾಯಕ ಕಾರ್ಯನಿರ್ವಾಹಕ ಅಭಿಯಂತರರು
ಯಶವಂತಪುರ ಉಪ ವಿಭಾಗ
ಬೃಹತ್ ಬೆಂಗಳೂರು [illegible]ಗರ ಪಾಲಿಕೆ

Scanned by CamScanner

CIVIL EXPERTS
ISO 9001:2008
CONSULTANTS & TESTING CENTER

174, Sri Ranga Complex
Amrutha Nagar Main Road
New Bank Colony, Konanakunte
Bangalore · 560 062.
Mobile : +91 97429 59595
Tele/Fax : 080-2632 2565
E-mail : civilexpertsltd@gmail.com
URL : www.civilexperts.in

NABL ACCREDITED AS PER ISO/IEC 17025:2005

JOB No: CECTC-PMC-NMK-2016-17 Dated: 28.02.2017

TEST REPORT FOR OGL SOIL

Client	:	**Executive Engineer,** Rajarajeshwarinagara Division, BBMP, Bangalore.
Agency	:	**Sri.N.M.Krishna Murthy,** Contractor, Bangalore.
Name of the Work	:	Modified Estimate for the Work of Development of Playground at Ward No.17 JP Park, BBMP, Bangalore.
Sample / Location	:	OGL Soil, -
Date of sample taken for testing	:	27.02.2017

The results of the test Conducted on the sample is as follows.

Sl. No.	Name of Test	Test as per IS Code	Test Results
1	Determination of water Content-Dry Density Relation using heavy Compaction	IS 2720 Part 8	MDD = 1.77 g/cc OMC = 11.00 %
2	Liquid Limit of soil %	IS 2720(Part -5)1985 RA 2010	35.00 %
3	Grain size analysis (By wet sieving)	IS 2720(Part -4)1985 RA 2010	Gravel in % = 9.77 Sand in % =55.68 Silt & clay in % =34.55

Note:

⇒ The report shall not be reproduced, except in full, without the written approval of the laboratory.

⇒ The results indicated above are based on the tests carried out on the samples received in the laboratory.

⇒ Any Query regarding the report must be reported within 15 days from the date of testing.

For Civil Expert

Lakshmi.G

Authorised Signature

ಸಹಾಯಕ ಕಾರ್ಯನಿರ್ವಾಹಕ ಅಭಿಯಂತರರು
ಯಶವಂತಪುರ ಉಪ ವಿಭಾಗ
ಬೃಹತ್ ಬೆಂಗಳೂರು ಮಹಾನಗರ ಪಾಲಿಕೆ

Scanned by CamScanner